



SAN MIGUEL CORPORATION

WEEKLY ENVIRONMENT WATCH

November 4-10, 2019

San Miguel Corporation's Limay CFB (Circulating Fluidized Bed) power plant undergoes daily emission testing. Average results for the week show its emissions are way below Department of Environment and Natural Resources and World Bank limits.

World Bank
limit
700 PPM

DENR limit
487 PPM

World Bank
limit
365 PPM

DENR limit
400 PPM

DENR limit
150.0 mg/Nm³

DENR
limit
245 PPM

World Bank
limit
50.0 mg/Nm³

SMC
71 PPM

SMC
56 PPM

SMC
18 PPM

SMC
2 mg/Nm³

Sulfur Oxide

Nitrogen
Oxide

Carbon
Monoxide

Particulate Matter
(Dust)